



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Sample Information:

Type : Potable Water

Lab No. : 1605098-001

Client Sample ID: WEIGHT ROOM/ FOUNTAIN/ R

Attn To : Nancy Henner

Origin: Distribution

Collected : 5/20/2016 5:40:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 5:44:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-002

Client Sample ID: GYM/ WATER BOTTLE
 FOUNTAIN/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-003
Client Sample ID: GYM/ FOUNTAIN/ R

Sample Information:
 Type : Potable Water

Attn To : Nancy Henner
 Collected : 5/20/2016 5:46:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-004
Client Sample ID: MENS LOCKER ROOM/ DF-1/ R

Sample Information:

Type : Potable Water
 Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 5:48:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-005
Client Sample ID: MENS LOCKER ROOM/ DF-2/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 5:51:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Sample Information:

Type : Potable Water

Lab No. : 1605098-006

Client Sample ID: DIST. OFFICE/ FOUNTAIN/ R

Attn To : Nancy Henner

Origin: Distribution

Collected : 5/20/2016 5:55:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-007
Client Sample ID: NURSES OFFICE/ SINK/ R

Sample Information:

Type : Potable Water

 Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:00:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	SUB :				<u>Analyst:</u>	Sub
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:01:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-008

Client Sample ID: ATTENDANCE/ HALL FOUNTAIN
 1/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

- Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:02:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-009

Client Sample ID: ATTENDANCE/ HALL FOUNTAIN
 2/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Sample Information:

Type : Potable Water

Lab No. : 1605098-010

Client Sample ID: FACULTY LOUNGE/ SINK/ R

Origin: Distribution

Attn To : Nancy Henner

Collected : 5/20/2016 6:04:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>	<u>Analyst:</u>	<u>Sub</u>			
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Sample Information:

Type : Potable Water

 Origin: Distribution

Lab No. : 1605098-011

**Client Sample ID: NORTH END DOWN/ FOUNTAIN
 1/ R**

Attn To : Nancy Henner

Collected : 5/20/2016 6:08:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Attn To : Nancy Henner
 Collected : 5/20/2016 6:10:00 AM
 Received : 5/24/2016 10:35:00 AM
 Collected By Client
 HANNIBAL HIGH SCHOOL

Lab No. : 1605098-012
Client Sample ID: NORTH END DOWN/ FOUNTAIN
2/ R

Sample Information:
 Type : Potable Water
 Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>	<u>Analyst:</u>	<u>Sub</u>			
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-013
Client Sample ID: HALL FOUNTAIN BY ICS/ R

Sample Information:
 Type : Potable Water

Attn To : Nancy Henner
 Collected : 5/20/2016 6:16:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-014
Client Sample ID: HALL FOUNTAIN BY 303/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:13:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:20:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Lab No. : 1605098-015

Client Sample ID: CHORUS ROOM/ FOUNTAIN/ R

Sample Information:

Type : Potable Water
 Origin: Distribution

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Analyst:</u>	<u>Sub</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016			Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:26:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-016

Client Sample ID: CAFETERIA/ DF-1/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-017
Client Sample ID: CAFETERIA/ DF-2/R

Sample Information:

Type : Potable Water

 Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:30:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>	<u>Analyst:</u>	<u>Sub</u>			
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:31:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-018
 Client Sample ID: KITCHEN/ SINK 1/ R

Sample Information:

Type : Potable Water

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-019
Client Sample ID: KITCHEN/ SINK 2/ R

Sample Information:
 Type : Potable Water

Attn To : Nancy Henner
 Collected : 5/20/2016 6:32:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-020
Client Sample ID: KITCHEN/ SINK 3/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:33:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-021
Client Sample ID: KITCHEN/ SINK 4/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:35:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-022
Client Sample ID: KITCHEN/ SINK 5/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 6:39:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-023
Client Sample ID: KITCHEN/ SINK 6/ R

Sample Information:
 Type : Potable Water

Attn To : Nancy Henner
 Collected : 5/20/2016 6:40:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:43:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-024
 Client Sample ID: KITCHEN/ HAND SINK/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

**928 Cayuga Street
Hannibal, NY 13074**

Attn To : Nancy Henner

Collected : 5/20/2016 6:49:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-025

**Client Sample ID: AUDITORIUM HALL/ FOUNTAIN
1/ R**

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:51:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-026

Client Sample ID: AUDITORIUM HALL/ FOUNTAIN
 2/ R

Sample Information:

Type : Potable Water

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:54:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-027
 Client Sample ID: ROOM 136/ SINK 1/ R

Sample Information:

Type : Potable Water

Origin: Distribution

Analytical Method: SUB :

Analyst: Sub

Parameter(s)	Results	Qualifier	D.F.	Units	Analyzed:	Container:
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District

928 Cayuga Street
 Hannibal, NY 13074

Attn To : Nancy Henner

Collected : 5/20/2016 6:55:00 AM

Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL

Collected By Client

Lab No. : 1605098-028
 Client Sample ID: ROOM 136/ SINK 2/ R

Sample Information:

Type : Potable Water

Origin: Distribution

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Analyst:</u>	<u>Sub</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016			Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-029
Client Sample ID: ROOM 136/ SINK 3/ R

Sample Information:
 Type : Potable Water

Attn To : Nancy Henner
 Collected : 5/20/2016 6:58:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

Origin: Distribution

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.
 This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Hannibal Central School District
928 Cayuga Street
Hannibal, NY 13074

Lab No. : 1605098-030
Client Sample ID: ROOM 136/ SINK 4/ R

Sample Information:
 Type : Potable Water

Origin: Distribution

Attn To : Nancy Henner
 Collected : 5/20/2016 7:00:00 AM
 Received : 5/24/2016 10:35:00 AM HANNIBAL HIGH SCHOOL
 Collected By Client

<u>Analytical Method:</u>	<u>SUB :</u>			<u>Analyst:</u>	<u>Sub</u>
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
					<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **CITI**

Date and Time Received: **5/24/2016 10:35:00 AM**

Work Order Number: **1605098**

RcptNo: **1**

Received by **Erick Johnson**

Completed by: *Jaclyn Kuri*

Reviewed by: *Elizabeth Harrison*

Completed Date: 5/25/2016 10:36:00 PM

Reviewed Date: 6/1/2016 11:10:47 AM

Carrier name: FedEx

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Are matrices correctly identified on Chain of custody? Yes No
- Is it clear what analyses were requested? Yes No
- Custody seals intact on sample bottles? Yes No Not Present
- Samples in proper container/bottle? Yes No
- Were correct preservatives used and noted? Yes No NA
- Preservative added to bottles:
- Sample Condition? Intact Broken Leaking
- Sufficient sample volume for indicated test? Yes No
- Were container labels complete (ID, Pres, Date)? Yes No
- All samples received within holding time? Yes No
- Was an attempt made to cool the samples? Yes No NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes No NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes No To °
- Water - Were bubbles absent in VOC vials? Yes No No Vials
- Water - Was there Chlorine Present? Yes No NA
- Water - pH acceptable upon receipt? Yes No No Water
- Are Samples considered acceptable? Yes No
- Custody Seals present? Yes No
- Airbill or Sticker? Air Bil Sticker Not Present
- Airbill No: 7763 5191 5721

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? Yes No NA Person Contacted:

Contact Mode: Phone: Fax: Email: In Person:

Client Instructions:

Date Contacted: Contacted By:

Regarding:

Comments:

Sample ID on chain says " KITCHEN/ SINK 2/F" Sample ID on bottle says "KITCHEN/SINK 2/ R" Sample is logged as per bottle

Sample ID on chain says " KITCHEN/ SINK 6/ F." Sample ID on bottle says " KITCHEN/ SINK 6/ R" Sample is logged as per bottle.

CorrectiveAction:

WorkOrder :
1605098

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



www.pacelabs.com

Section A
 Required Client Information:
 Company: Hannibal CSD
 Address: 928 Cayuga St
 Hannibal, NY 13074
 Email To: mhenner@hannibalcsd.org
 Phone: 564-7977
 Fax:

Section B
 Required Project Information:
 Report To:
 Copy To:
 Purchase Order No.:
 Project Name: Hannibal High School
 Project Number:
 Requested Due Date/TAT: 10 days

Section C
 Invoice Information:
 Attention:
 Company Name: CITI BOCES
 Address:
 Pace Quote Reference:
 Pace Project Manager:
 Pace Profile #:

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER

SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER NY

# ITEM	Valid Matrix Codes MATRIX DRINKING WATER WATER WATER PRODUCT SOLUBLE OIL AIR AIR OTHER TISSUE	CODE DW WT WP SL VL VP AR AT OT TS	MATRIX TYPE	COLLECTED		# OF CONTAINERS	PRESERVATIVES							Requested Ant FB	Filtered (Y/N)	Temp in C	Received on Ice	Custody Sealed	Samples Intact	
				COMPOSITE START	COMPOSITE END/GRAB		H2SO4	HNO3	HCl	NaOH	Na2S2O8	Methanol	Na2SO4							DATE
1	WEIGHT ROOM / FOUNTAIN / R	DW	G	5/20	5:40	1														
2	WEIGHT ROOM / FOUNTAIN / F	DW	G		5:41	1														
3	GYM / WATER BOTTLE FOUNTAIN / R	DW	G		5:44	1														
4	GYM / WATER BOTTLE FOUNTAIN / F	DW	G		5:45	1														
5	GYM / FOUNTAIN / R	DW	G		5:46	1														
6	GYM / FOUNTAIN / F	DW	G		5:47	1														
7	MENS LOCKER ROOM / DF-1 / R	DW	G		5:48	1														
8	MENS LOCKER ROOM / DF-1 / F	DW	G		5:50	1														
9	MENS LOCKER ROOM / DF-2 / R	DW	G		5:51	1														
10	MENS LOCKER ROOM / DF-2 / F	DW	G		5:52	1														
11	DIST.OFFICE / FOUNTAIN / R	DW	G		5:55	1														
12	DIST.OFFICE / FOUNTAIN / F	DW	G		5:57	1														

ADDITIONAL COMMENTS
 Samples ending in F are flushed samples and are to be held pending the results of the raw samples.

RELINQUISHED BY / AFFILIATION
 J. P. Pace
 DATE: 5/23/16
 TIME: 17:00

ACCEPTED BY / AFFILIATION
 J. P. Pace
 DATE: 5/23/16
 TIME: 10:23

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy PACE
 SIGNATURE of SAMPLER: *James Murphy*
 DATE Signed (MM / DD / YY): 5/20/16

7763 5191 5721

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A
Required Client Information:
 Company: Hannibal CSD
 Address: 928 Cayuga St
 Hannibal, NY 13074
 Email To: mhennet@hannibalcsd.org
 Phone: 564-7977
 Fax:

Section B
Required Project Information:
 Report To:
 Copy To:
 Purchase Order No.:
 Project Name: Hannibal High School
 Project Number:

Section C
Invoice Information:
 Attention:
 Company Name: CITI BOCES
 Address:
 Pace Quote Reference:
 Pace Project Manager:
 Pace Profile #:

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER

SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER_NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX	CODE	COLLECTED		# OF CONTAINERS	PRESERVATIVES						Requested Analyte	Pace Project No. Lab ID.
					COMPOSITE START	COMPOSITE END/GRAB		Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ SO ₄		
	SAMPLE ID (A-Z, 0-9 / -)				DATE	TIME									
1	NURSES NURSE OFFICE / SINK / R			DW	5/20	6:00	1								1105008
2	NURSES NURSE OFFICE / SINK / F			DW		6:00	1								
3	ATTENDANCE / HALL FOUNTAIN 1 / R			DW		6:01	1								
4	ATTENDANCE / HALL FOUNTAIN 1 / F			DW		6:01	1								
5	ATTENDANCE / HALL FOUNTAIN 2 / R			DW		6:02	1								
6	ATTENDANCE / HALL FOUNTAIN 2 / F			DW		6:03	1								
7	FACULTY LOUNGE / SINK / R			DW		6:04	1								
8	FACULTY LOUNGE / SINK / F			DW		6:05	1								
9	NORTH END DOWN / FOUNTAIN 1 / R			DW		6:08	1								
10	NORTH END DOWN / FOUNTAIN 1 / F			DW		6:09	1								
11	NORTH END DOWN / FOUNTAIN 2 / R			DW		6:10	1								
12	NORTH END DOWN / FOUNTAIN 2 / F			DW		6:11	1								

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
7763 5191 5721 Samples ending in F are flushed samples and are to be held pending the results of the raw samples.	<i>James Murphy Pace</i>	5/20/16	1700	<i>James Murphy Pace</i>	5/29	1635	Received on Ice Y/N Custody Sealed Y/N Cooler Y/N Samples Intact Y/N

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: *James Murphy Pace*
 SIGNATURE of SAMPLER: *James Murphy*
 DATE Signed (MM / DD / YY): *5/20/16*

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



www.pacelabs.com

Section A
 Required Client Information:
 Company: Hannibal CSD
 Address: 928 Cayuga St
 Hannibal, NY 13074
 Email To: mhemmer@hannibalcsd.org
 Phone: 564-7977
 Requested Due Date/TAT: 10 days

Section B
 Required Project Information:
 Report To:
 Copy To:
 Purchase Order No.:
 Project Name: Hannibal High School
 Project Number:

Section C
 Invoice Information:
 Attention:
 Company Name: CITI BOCES
 Address:
 Pace Quote Reference:
 Pace Project Manager:
 Pace Profile #:

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER

SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER_NY

Filtered (Y/N)
Requested
 Ane
 Residual Chlorine (Y/N)
 Pace Project No. Lab I.D.
 1605098

ITEM #	Valid Matrix Codes MATRIX DRINKING WATER WATER WV P SL PRODUCT SOLID WV AR S T T2	CODE	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES							ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS							
			MATRIX CODE	SAMPLE TYPE			COMPOSITE START	COMPOSITE END/GRAB	DATE	TIME	DATE	TIME	DATE					TIME	DATE	TIME				
1	HALL FOUNTAIN BY ICS / R	DW	G	5/20	6:16	1	Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₅	Methanol	Na ₂ SO ₄	X			Received on Ice	Y/N	Custody Sealed	Y/N	Samples Intact	Y/N	
2	HALL FOUNTAIN BY ICS / F	DW	G		6:17	1																		
3	HALL FOUNTAIN BY ROOM 303 / R	DW	G		6:13	1																		
4	HALL FOUNTAIN BY ROOM 303 / F	DW	G		6:14	1																		
5	CHORUS ROOM / FOUNTAIN / R	DW	G		6:20	1																		
6	CHORUS ROOM / FOUNTAIN / F	DW	G		6:22	1																		
7	CAFETERIA / DF-1 / R	DW	G		6:26	1																		
8	CAFETERIA / DF-1 / F	DW	G		6:27	1																		
9	CAFETERIA / DF-2 / R	DW	G		6:30	1																		
10	CAFETERIA / DF-2 / F	DW	G		6:30	1																		
11	KITCHEN / SINK 1 / R	DW	G		6:31	1																		
12	KITCHEN / SINK 1 / F	DW	G		6:31	1																		

ADDITIONAL COMMENTS
 Samples ending in F are flushed samples and are to be held pending the results of the raw samples.

RELINQUISHED BY / AFFILIATION
 James Murphy Pace
 5/20/16 12:00

ACCEPTED BY / AFFILIATION
 [Signature]

DATE
 5/29/16

TIME
 1:30

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy Pace
 SIGNATURE of SAMPLER: [Signature]
 DATE Signed (MM/DD/YY): 5/20/16

7763 5191 5221

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company: Hannibal CSD		Report To:		Attention:	
Address: 928 Cayuga St		Copy To:		Company Name: CITI BOCES	
Hannibal, NY 13074		Purchase Order No.:		Address:	
Email To: rhenner@hannibalcsd.org		Project Name: Hannibal High School		Pace Quote Reference:	
Phone: 564-7977		Project Number:		Pace Project Manager:	
Requested Due Date/TAT: 10 days		Matrix Code:		Pace Profile #:	

REGULATORY AGENCY

NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER _____

SITE LOCATION
 GA IL IN MI NC
 OH SC WI OTHER_NY _____

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX	CODE	COLLECTED		# OF CONTAINERS	PRESERVATIVES						Requested Ant	Filtered (Y/N)	Temp In °C	Received on Ice	Custody Sealed	Samples Intact
					COMPOSITE START	COMPOSITE END/GRAB		Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₈						
	SAMPLE ID (A-Z, 0-9 / -)				DATE	TIME													
1	KITCHEN / SINK 2 / F	DW	G	DW	5/20	6:32	1												
2	KITCHEN / SINK 2 / F	DW	G	DW		6:32	1												
3	KITCHEN / SINK 3 / R	DW	G	DW		6:33	1												
4	KITCHEN / SINK 3 / F	DW	G	DW		6:34	1												
5	KITCHEN / SINK 4 / R	DW	G	DW		6:35	1												
6	KITCHEN / SINK 4 / F	DW	G	DW		6:37	1												
7	KITCHEN / SINK 5 / R	DW	G	DW		6:39	1												
8	KITCHEN / SINK 5 / F	DW	G	DW		6:39	1												
9	KITCHEN / SINK 6 / F	DW	G	DW		6:40	1												
10	KITCHEN / SINK 6 / F	DW	G	DW		6:40	1												
11	KITCHEN / HAND SINK / R	DW	G	DW		6:43	1												
12	KITCHEN / HAND SINK / F	DW	G	DW		6:44	1												

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
Samples ending in F are flushed samples and are to be held pending the results of the raw samples.	James Murphy PACE	5/23/16	17:00	SEE PR	5/24	10:35	Y/N
							Y/N
							Y/N
							Y/N
							Y/N
							Y/N
							Y/N
							Y/N
							Y/N

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: James Murphy PACE

SIGNATURE of SAMPLER: [Signature]

DATE Signed (MM/DD/YY): 5/20/16

7763 5191 5721



CHAIN-OF-CUSTODY / Analytical Request Document
 The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 5 of 5

Section A
 Required Client Information:
 Company: Hannibal CSD
 Address: 928 Cayuga St
 Hannibal, NY 13074
 Email To: rhenner@hannibalcsd.org
 Phone: 564-7977
 Fax:

Section B
 Required Project Information:
 Report To:
 Copy To:
 Purchase Order No.:
 Project Name: Hannibal High School
 Project Number:
 Requested Due Date/TAT: 10 days

Section C
 Invoice Information:
 Attention:
 Company Name: CITI BOCES
 Address:
 Pace Quote Reference:
 Pace Project Manager:
 Pace Profile #:

REGULATORY AGENCY
 NPDES GROUND WATER DRINKING WATER
 UST RCRA OTHER

SITE
 GA IL IN MI NC
 OH SC WI OTHER_NY

LOCATION

Filtered (Y/N)

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX	CODE	COLLECTED		# OF CONTAINERS	PRESERVATIVES	Requested Analytes	Pace Project No. Lab I.D.	
					COMPOSITE START	COMPOSITE ENDIGRAB					
					DATE	TIME					
1	AUDITORIUM HALL / FOUNTAIN 1 / R	DW	G	DW	G	5/20	6:49	1	Unpreserved H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Na ₂ SO ₄	X	
2	AUDITORIUM HALL / FOUNTAIN 1 / F	DW	G	DW	G		6:49	1		X	
3	AUDITORIUM HALL / FOUNTAIN 2 / R	DW	G	DW	G		6:51	1		X	
4	AUDITORIUM HALL / FOUNTAIN 2 / F	DW	G	DW	G		6:51	1		X	
5	ROOM 136 / SINK 1 / R	DW	G	DW	G		6:54	1		X	
6	ROOM 136 / SINK 1 / F	DW	G	DW	G		6:55	1		X	
7	ROOM 136 / SINK 2 / R	DW	G	DW	G		6:55	1		X	
8	ROOM 136 / SINK 2 / F	DW	G	DW	G		6:56	1		X	
9	ROOM 136 / SINK 3 / R	DW	G	DW	G		6:58	1		X	
10	ROOM 136 / SINK 3 / F	DW	G	DW	G		6:58	1		X	
11	ROOM 136 / SINK 4 / R	DW	G	DW	G		7:00	1		X	
12	ROOM 136 / SINK 4 / F	DW	G	DW	G		7:00	1		X	

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>James Murphy</i>	5/23/16	17:00	<i>PACE</i>	5/24	10:33	Received on Ice Custody Sealed Cooler
							Temp in °C
							Samples Intact

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: James Murphy
 SIGNATURE of SAMPLER: *James Murphy*
 DATE Signed (MM/DD/YY): 5/20/16

7763 SIG 1521

June 09, 2016

Betty Harrison
Pace Analytical Melville
575 Broad Hollow Road
Melville, NY 11747

RE: Project: 1605O98
Pace Project No.: 35247892

Dear Betty Harrison:

Enclosed are the analytical results for sample(s) received by the laboratory on June 07, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current TNI standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Bo Garcia
bo.garcia@pacelabs.com
Project Manager

Enclosures

cc: Jennifer Aracri, Pace Analytical Melville
Caitlin Hutchinson, Pace Analytical Services, Inc.
Stu Murrell, Pace Analytical Services, Inc.
Susan Richter, Pace Analytical Services, Inc.
Joann Slavin, Pace Analytical Melville
Sophia Sparks, Pace Analytical Services, Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

CERTIFICATIONS

Project: 1605098

Pace Project No.: 35247892

Ormond Beach Certification IDs

8 East Tower Circle, Ormond Beach, FL 32174
Alabama Certification #: 41320
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maryland Certification: #346
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236
Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14
Nevada Certification: FL NELAC Reciprocity
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
Wyoming Certification: FL NELAC Reciprocity
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

SAMPLE SUMMARY

Project: 1605098
Pace Project No.: 35247892

Lab ID	Sample ID	Matrix	Date Collected	Date Received
35247892001	WEIGHT ROOM/ FOUNTAN/ R	Drinking Water	05/20/16 05:40	06/07/16 07:05
35247892002	GYM/ WATER BOTTLE FOUNTAN/ R	Drinking Water	05/20/16 05:44	06/07/16 07:05
35247892003	GYM/ FOUNTAN/ R	Drinking Water	05/20/16 05:46	06/07/16 07:05
35247892004	MENS LOCKER ROOM/ DF-1/ R	Drinking Water	05/20/16 05:48	06/07/16 07:05
35247892005	MENS LOCKER ROOM/ DF-2/ R	Drinking Water	05/20/16 05:51	06/07/16 07:05
35247892006	DIST. OFFICE/ FOUNTAIN/ R	Drinking Water	05/20/16 05:55	06/07/16 07:05
35247892007	NURSES OFFICE/ SINK/ R	Drinking Water	05/20/16 06:00	06/07/16 07:05
35247892008	ATTENDANCE/ HALL FOUNTAIN 1/ R	Drinking Water	05/20/16 06:01	06/07/16 07:05
35247892009	ATTENDANCE/ HALL FOUNTAIN 2/ R	Drinking Water	05/20/16 06:02	06/07/16 07:05
35247892010	FACULTY LOUNGE/ SINK/ R	Drinking Water	05/20/16 06:04	06/07/16 07:05
35247892011	NORTH END DOWN/ FOUNTAIN 1/ R	Drinking Water	05/20/16 06:08	06/07/16 07:05
35247892012	NORTH END DOWN/ FOUNTAIN 2/ R	Drinking Water	05/20/16 06:10	06/07/16 07:05
35247892013	HALL FOUNTAIN BY ICS/ R	Drinking Water	05/20/16 06:16	06/07/16 07:05
35247892014	HALL FOUNTAIN BY 303/ R	Drinking Water	05/20/16 06:13	06/07/16 07:05
35247892015	CHORUS ROOM/ FOUNTAIN/ R	Drinking Water	05/20/16 06:20	06/07/16 07:05
35247892016	CAFETERIA/ DF-1/ R	Drinking Water	05/20/16 06:26	06/07/16 07:05
35247892017	CAFETERIA/ DF-2/ R	Drinking Water	05/20/16 06:30	06/07/16 07:05
35247892018	KITCHEN/ SINK 1/ R	Drinking Water	05/20/16 06:31	06/07/16 07:05
35247892019	KITCHEN/ SINK 2/ R	Drinking Water	05/20/16 06:32	06/07/16 07:05
35247892020	KITCHEN/ SINK 3/ R	Drinking Water	05/20/16 06:33	06/07/16 07:05
35247892021	KITCHEN/ SINK 4/ R	Drinking Water	05/20/16 06:35	06/07/16 07:05
35247892022	KITCHEN/ SINK 5/ R	Drinking Water	05/20/16 06:39	06/07/16 07:05
35247892023	KITCHEN/ SINK 6/ R	Drinking Water	05/20/16 06:40	06/07/16 07:05
35247892024	KITCHEN/ HAND SINK/ R	Drinking Water	05/20/16 06:43	06/07/16 07:05
35247892025	AUDITORIUM HALL/ FOUNTAIN 1/ R	Drinking Water	05/20/16 06:49	06/07/16 07:05
35247892026	AUDITORIUM HALL/ FOUNTAIN 2/ R	Drinking Water	05/20/16 06:51	06/07/16 07:05
35247892027	ROOM 136/ SINK 1/ R	Drinking Water	05/20/16 06:54	06/07/16 07:05
35247892028	ROOM 136/ SINK 2/ R	Drinking Water	05/20/16 06:55	06/07/16 07:05
35247892029	ROOM 136/ SINK 3/ R	Drinking Water	05/20/16 06:58	06/07/16 07:05
35247892030	ROOM 136/ SINK 4/ R	Drinking Water	05/20/16 07:00	06/07/16 07:05

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

SAMPLE ANALYTE COUNT

Project: 1605098
Pace Project No.: 35247892

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35247892001	WEIGHT ROOM/ FOUNTAN/ R	EPA 200.8	DRS	1	PASI-O
35247892002	GYM/ WATER BOTTLE FOUNTAN/ R	EPA 200.8	DRS	1	PASI-O
35247892003	GYM/ FOUNTAN/ R	EPA 200.8	DRS	1	PASI-O
35247892004	MENS LOCKER ROOM/ DF-1/ R	EPA 200.8	DRS	1	PASI-O
35247892005	MENS LOCKER ROOM/ DF-2/ R	EPA 200.8	DRS	1	PASI-O
35247892006	DIST. OFFICE/ FOUNTAIN/ R	EPA 200.8	DRS	1	PASI-O
35247892007	NURSES OFFICE/ SINK/ R	EPA 200.8	DRS	1	PASI-O
35247892008	ATTENDANCE/ HALL FOUNTAIN 1/ R	EPA 200.8	DRS	1	PASI-O
35247892009	ATTENDANCE/ HALL FOUNTAIN 2/ R	EPA 200.8	DRS	1	PASI-O
35247892010	FACULTY LOUNGE/ SINK/ R	EPA 200.8	DRS	1	PASI-O
35247892011	NORTH END DOWN/ FOUNTAIN 1/ R	EPA 200.8	DRS	1	PASI-O
35247892012	NORTH END DOWN/ FOUNTAIN 2/ R	EPA 200.8	CKJ	1	PASI-O
35247892013	HALL FOUNTAIN BY ICS/ R	EPA 200.8	CKJ	1	PASI-O
35247892014	HALL FOUNTAIN BY 303/ R	EPA 200.8	CKJ	1	PASI-O
35247892015	CHORUS ROOM/ FOUNTAIN/ R	EPA 200.8	CKJ	1	PASI-O
35247892016	CAFETERIA/ DF-1/ R	EPA 200.8	CKJ	1	PASI-O
35247892017	CAFETERIA/ DF-2/ R	EPA 200.8	CKJ	1	PASI-O
35247892018	KITCHEN/ SINK 1/ R	EPA 200.8	CKJ	1	PASI-O
35247892019	KITCHEN/ SINK 2/ R	EPA 200.8	CKJ	1	PASI-O
35247892020	KITCHEN/ SINK 3/ R	EPA 200.8	CKJ	1	PASI-O
35247892021	KITCHEN/ SINK 4/ R	EPA 200.8	CKJ	1	PASI-O
35247892022	KITCHEN/ SINK 5/ R	EPA 200.8	CKJ	1	PASI-O
35247892023	KITCHEN/ SINK 6/ R	EPA 200.8	CKJ	1	PASI-O
35247892024	KITCHEN/ HAND SINK/ R	EPA 200.8	CKJ	1	PASI-O
35247892025	AUDITORIUM HALL/ FOUNTAIN 1/ R	EPA 200.8	CKJ	1	PASI-O
35247892026	AUDITORIUM HALL/ FOUNTAIN 2/ R	EPA 200.8	CKJ	1	PASI-O
35247892027	ROOM 136/ SINK 1/ R	EPA 200.8	CKJ	1	PASI-O
35247892028	ROOM 136/ SINK 2/ R	EPA 200.8	CKJ	1	PASI-O
35247892029	ROOM 136/ SINK 3/ R	EPA 200.8	CKJ	1	PASI-O
35247892030	ROOM 136/ SINK 4/ R	EPA 200.8	CKJ	1	PASI-O

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: WEIGHT ROOM/
FOUNTAIN/ R **Lab ID:** 35247892001 Collected: 05/20/16 05:40 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 23:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: GYM/ WATER BOTTLE **Lab ID:** 35247892002 Collected: 05/20/16 05:44 Received: 06/07/16 07:05 Matrix: Drinking Water
FOUNTAN/ R

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 23:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: GYM/ FOUNTAN/ R **Lab ID: 35247892003** Collected: 05/20/16 05:46 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	5.2	ug/L	1.0	0.50	1		06/08/16 23:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: MENS LOCKER ROOM/DF-1/ R **Lab ID:** 35247892004 Collected: 05/20/16 05:48 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.2	ug/L	1.0	0.50	1		06/08/16 23:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: MENS LOCKER ROOM/DF-2/ R **Lab ID:** 35247892005 Collected: 05/20/16 05:51 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	4.5	ug/L	1.0	0.50	1		06/08/16 23:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: DIST. OFFICE/ FOUNTAIN/
R **Lab ID:** 35247892006 Collected: 05/20/16 05:55 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	1.1	ug/L	1.0	0.50	1		06/08/16 23:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: NURSES OFFICE/ SINK/ R **Lab ID: 35247892007** Collected: 05/20/16 06:00 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.9	ug/L	1.0	0.50	1		06/08/16 23:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098
Pace Project No.: 35247892

Sample: ATTENDANCE/ HALL FOUNTAIN 1/ R **Lab ID:** 35247892008 Collected: 05/20/16 06:01 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 23:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098
Pace Project No.: 35247892

Sample: ATTENDANCE/ HALL FOUNTAIN 2/ R **Lab ID:** 35247892009 Collected: 05/20/16 06:02 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 23:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: FACULTY LOUNGE/ SINK/ R **Lab ID:** 35247892010 Collected: 05/20/16 06:04 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.0	ug/L	1.0	0.50	1		06/08/16 23:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: NORTH END DOWN/
FOUNTAIN 1/ R **Lab ID:** 35247892011 Collected: 05/20/16 06:08 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 23:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: NORTH END DOWN/
FOUNTAIN 2/ R **Lab ID:** 35247892012 Collected: 05/20/16 06:10 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: HALL FOUNTAIN BY ICS/ R **Lab ID:** 35247892013 Collected: 05/20/16 06:16 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: HALL FOUNTAIN BY 303/ R Lab ID: 35247892014 Collected: 05/20/16 06:13 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: CHORUS ROOM/
FOUNTAIN/ R **Lab ID:** 35247892015 Collected: 05/20/16 06:20 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	2.5	ug/L	1.0	0.50	1		06/09/16 11:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098
Pace Project No.: 35247892

Sample: CAFETERIA/ DF-1/ R **Lab ID: 35247892016** Collected: 05/20/16 06:26 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098
Pace Project No.: 35247892

Sample: CAFETERIA/ DF-2/ R **Lab ID: 35247892017** Collected: 05/20/16 06:30 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 1/ R **Lab ID: 35247892018** Collected: 05/20/16 06:31 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	12.3	ug/L	1.0	0.50	1		06/09/16 11:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 2/ R **Lab ID: 35247892019** Collected: 05/20/16 06:32 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.3	ug/L	1.0	0.50	1		06/09/16 11:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 3/ R **Lab ID: 35247892020** Collected: 05/20/16 06:33 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	6.5	ug/L	1.0	0.50	1		06/09/16 11:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 4/ R **Lab ID: 35247892021** Collected: 05/20/16 06:35 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	2.5	ug/L	1.0	0.50	1		06/09/16 11:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 5/ R **Lab ID: 35247892022** Collected: 05/20/16 06:39 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.2	ug/L	1.0	0.50	1		06/09/16 11:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ SINK 6/ R **Lab ID: 35247892023** Collected: 05/20/16 06:40 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	6.8	ug/L	1.0	0.50	1		06/09/16 11:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: KITCHEN/ HAND SINK/ R **Lab ID: 35247892024** Collected: 05/20/16 06:43 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	3.2	ug/L	1.0	0.50	1		06/09/16 11:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: AUDITORIUM HALL/
FOUNTAIN 1/ R **Lab ID:** 35247892025 Collected: 05/20/16 06:49 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: AUDITORIUM HALL/
FOUNTAIN 2/ R **Lab ID:** 35247892026 Collected: 05/20/16 06:51 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/09/16 11:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: ROOM 136/ SINK 1/ R **Lab ID: 35247892027** Collected: 05/20/16 06:54 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	6.1	ug/L	1.0	0.50	1		06/09/16 11:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: ROOM 136/ SINK 2/ R **Lab ID: 35247892028** Collected: 05/20/16 06:55 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	10.4	ug/L	1.0	0.50	1		06/09/16 12:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: ROOM 136/ SINK 3/ R **Lab ID: 35247892029** Collected: 05/20/16 06:58 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	8.6	ug/L	1.0	0.50	1		06/09/16 12:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605098

Pace Project No.: 35247892

Sample: ROOM 136/ SINK 4/ R **Lab ID: 35247892030** Collected: 05/20/16 07:00 Received: 06/07/16 07:05 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	6.8	ug/L	1.0	0.50	1		06/09/16 12:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA

Project: 1605098

Pace Project No.: 35247892

QC Batch: ICPM/12503 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Associated Lab Samples: 35247892001, 35247892002, 35247892003, 35247892004, 35247892005, 35247892006, 35247892007, 35247892008, 35247892009, 35247892010, 35247892011

METHOD BLANK: 1599037 Matrix: Water
 Associated Lab Samples: 35247892001, 35247892002, 35247892003, 35247892004, 35247892005, 35247892006, 35247892007, 35247892008, 35247892009, 35247892010, 35247892011

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	0.50	06/08/16 22:37	

LABORATORY CONTROL SAMPLE: 1599038

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1599039 1599040

Parameter	Units	35247891051 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	<1.0	50	50	54.3	54.1	108	108	70-130	0	20	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1599041 1599042

Parameter	Units	35247892002 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	<1.0	50	50	54.4	54.0	107	106	70-130	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA

Project: 1605098
Pace Project No.: 35247892

QC Batch: ICPM/12505 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Associated Lab Samples: 35247892012, 35247892013, 35247892014, 35247892015, 35247892016, 35247892017, 35247892018, 35247892019, 35247892020, 35247892021, 35247892022, 35247892023, 35247892024, 35247892025, 35247892026, 35247892027, 35247892028, 35247892029, 35247892030

METHOD BLANK: 1599423 Matrix: Water
Associated Lab Samples: 35247892012, 35247892013, 35247892014, 35247892015, 35247892016, 35247892017, 35247892018, 35247892019, 35247892020, 35247892021, 35247892022, 35247892023, 35247892024, 35247892025, 35247892026, 35247892027, 35247892028, 35247892029, 35247892030

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	0.50	06/09/16 11:09	

LABORATORY CONTROL SAMPLE: 1599424

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1599425 1599426

Parameter	Units	35247892012 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	<1.0	50	50	54.5	54.7	107	108	70-130	0	20	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1599427 1599428

Parameter	Units	35247892022 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	3.2	50	50	50.1	51.1	94	96	70-130	2	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALIFIERS

Project: 1605098
Pace Project No.: 35247892

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-O Pace Analytical Services - Ormond Beach

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 1605098
Pace Project No.: 35247892

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35247892001	WEIGHT ROOM/ FOUNTAIN/ R	EPA 200.8	ICPM/12503		
35247892002	GYM/ WATER BOTTLE FOUNTAIN/ R	EPA 200.8	ICPM/12503		
35247892003	GYM/ FOUNTAIN/ R	EPA 200.8	ICPM/12503		
35247892004	MENS LOCKER ROOM/ DF-1/ R	EPA 200.8	ICPM/12503		
35247892005	MENS LOCKER ROOM/ DF-2/ R	EPA 200.8	ICPM/12503		
35247892006	DIST. OFFICE/ FOUNTAIN/ R	EPA 200.8	ICPM/12503		
35247892007	NURSES OFFICE/ SINK/ R	EPA 200.8	ICPM/12503		
35247892008	ATTENDANCE/ HALL FOUNTAIN 1/ R	EPA 200.8	ICPM/12503		
35247892009	ATTENDANCE/ HALL FOUNTAIN 2/ R	EPA 200.8	ICPM/12503		
35247892010	FACULTY LOUNGE/ SINK/ R	EPA 200.8	ICPM/12503		
35247892011	NORTH END DOWN/ FOUNTAIN 1/ R	EPA 200.8	ICPM/12503		
35247892012	NORTH END DOWN/ FOUNTAIN 2/ R	EPA 200.8	ICPM/12505		
35247892013	HALL FOUNTAIN BY ICS/ R	EPA 200.8	ICPM/12505		
35247892014	HALL FOUNTAIN BY 303/ R	EPA 200.8	ICPM/12505		
35247892015	CHORUS ROOM/ FOUNTAIN/ R	EPA 200.8	ICPM/12505		
35247892016	CAFETERIA/ DF-1/ R	EPA 200.8	ICPM/12505		
35247892017	CAFETERIA/ DF-2/ R	EPA 200.8	ICPM/12505		
35247892018	KITCHEN/ SINK 1/ R	EPA 200.8	ICPM/12505		
35247892019	KITCHEN/ SINK 2/ R	EPA 200.8	ICPM/12505		
35247892020	KITCHEN/ SINK 3/ R	EPA 200.8	ICPM/12505		
35247892021	KITCHEN/ SINK 4/ R	EPA 200.8	ICPM/12505		
35247892022	KITCHEN/ SINK 5/ R	EPA 200.8	ICPM/12505		
35247892023	KITCHEN/ SINK 6/ R	EPA 200.8	ICPM/12505		
35247892024	KITCHEN/ HAND SINK/ R	EPA 200.8	ICPM/12505		
35247892025	AUDITORIUM HALL/ FOUNTAIN 1/ R	EPA 200.8	ICPM/12505		
35247892026	AUDITORIUM HALL/ FOUNTAIN 2/ R	EPA 200.8	ICPM/12505		
35247892027	ROOM 136/ SINK 1/ R	EPA 200.8	ICPM/12505		
35247892028	ROOM 136/ SINK 2/ R	EPA 200.8	ICPM/12505		
35247892029	ROOM 136/ SINK 3/ R	EPA 200.8	ICPM/12505		
35247892030	ROOM 136/ SINK 4/ R	EPA 200.8	ICPM/12505		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..



CHAIN OF CUSTODY RECORD


COC ID: 5243

PAGE: 1

OF: 5

ADDRESS
PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040
 FAX: (631) 420-8436
 Website: www.pacelabs.com

NO#: 35247892



35247892

Please Include Email Address of Report

SUB CONTRACTOR **Pace-Ormond Beach** COMPANY **Pace-Ormond Beach**

ADDRESS **8 East Tower Circle**

CITY, STATE, ZIP **Ormond Beach, FL 32174**

PHONE **(386) 672-5668** FAX **(386) 673-4001**

ACCOUNT # **70-100281** EMAIL

SPECIAL INSTRUCTIONS / COMMENTS:
 Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!
PH verified

ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
1	1605098-001A 200.8_DW_RT (E200.8)	WEIGHT ROOM/ FOUNTAIN/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:40:00 AM	1	
2	1605098-002A 200.8_DW_RT (E200.8)	GYM/ WATER BOTTLE FOUNTAIN/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:44:00 AM	1	
3	1605098-003A 200.8_DW_RT (E200.8)	GYM/ FOUNTAIN/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:46:00 AM	1	
4	1605098-004A 200.8_DW_RT (E200.8)	MENS LOCKER ROOM/ DF-1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:48:00 AM	1	
5	1605098-005A 200.8_DW_RT (E200.8)	MENS LOCKER ROOM/ DF-2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:51:00 AM	1	
6	1605098-006A 200.8_DW_RT (E200.8)	DIST. OFFICE/ FOUNTAIN/ R	250mlHDPEHN O3	Potable Water	5/20/2016 5:55:00 AM	1	

Relinquished By: *[Signature]* Date: *6/17/16* Time: *10:50*

Relinquished By: *[Signature]* Date: *6/17/16* Time: *10:50*

Relinquished By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

TAT: Standard RUSH 3rd BD

Next BD 2nd BD 3rd BD

Note: RUSH requests will incur surcharges!

REPORT TRANSMITTAL DESIRED:
 HARDCOPY (extra cost) FAX EMAIL ONLINE

FOR LAB USE ONLY
 Temp of samples *23.3* °C Attempt to Cool? *5-221*
 Comments: _____

CHAIN OF CUSTODY RECORD

COC ID: 5243

PAGE: 2

OF: 5

ADDRESS
PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040
 FAX: (631) 420-8436
 Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR: Pace-Ormond Beach		COMPANY: Pace-Ormond Beach	
ADDRESS: 8 East Tower Circle			
CITY, STATE, ZIP: Ormond Beach, FL 32174			
PHONE: (386) 672-5668	FAX: (386) 673-4001		
ACCOUNT #: 70-100281			

SPECIAL INSTRUCTIONS / COMMENTS:
 Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!

ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
7	1605098-007A 200.8_DW_RT (E200.8)	NURSES OFFICE/ SINK/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:00:00 AM	1	
8	1605098-008A 200.8_DW_RT (E200.8)	ATTENDANCE/ HALL FOUNTAIN 1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:01:00 AM	1	
9	1605098-009A 200.8_DW_RT (E200.8)	ATTENDANCE/ HALL FOUNTAIN 2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:02:00 AM	1	
10	1605098-010A 200.8_DW_RT (E200.8)	FACULTY LOUNGE/ SINK/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:04:00 AM	1	
11	1605098-011A 200.8_DW_RT (E200.8)	NORTH END DOWN/ FOUNTAIN 1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:08:00 AM	1	
12	1605098-012A 200.8_DW_RT (E200.8)	NORTH END DOWN/ FOUNTAIN 2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:10:00 AM	1	

Relinquished By: <i>[Signature]</i>	Date: <i>6/16/16</i>	Time: <i>10:50</i>	Received By: <i>[Signature]</i>	Date: <i>6/17/16</i>	Time: <i>10:50</i>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
TAT: Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>	

REPORT TRANSMITTAL DESIRED:
 HARDCOPY (extra cost) FAX EMAIL ONLINE

FOR LAB USE ONLY
 Temp of samples: *23.3* °C Attempt to Cool?
 Comments: *T-221*

Note: RUSH requests will incur surcharges!



CHAIN OF CUSTODY RECORD

COC ID: 5243

PAGE: 3

OF: 5

ADDRESS
PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040
 FAX: (631) 420-8436
 Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR: Pace-Ormond Beach COMPANY: Pace-Ormond Beach	
ADDRESS: 8 East Tower Circle	
CITY, STATE, ZIP: Ormond Beach, FL 32174	FAX: (386) 673-4001
PHONE: (386) 672-5668	EMAIL:
ACCOUNT #: 70-100281	

SPECIAL INSTRUCTIONS / COMMENTS:
 Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!

ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
13	1605098-013A 200.8_DW_RT (E200.8)	HALL FOUNTAIN BY ICS/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:16:00 AM	1	
14	1605098-014A 200.8_DW_RT (E200.8)	HALL FOUNTAIN BY 303/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:13:00 AM	1	
15	1605098-015A 200.8_DW_RT (E200.8)	CHORUS ROOM/ FOUNTAIN/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:20:00 AM	1	
16	1605098-016A 200.8_DW_RT (E200.8)	CAFETERIA/ DF-1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:26:00 AM	1	
17	1605098-017A 200.8_DW_RT (E200.8)	CAFETERIA/ DF-2/R	250mlHDPEHN O3	Potable Water	5/20/2016 6:30:00 AM	1	
18	1605098-018A 200.8_DW_RT (E200.8)	KITCHEN/ SINK 1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:31:00 AM	1	

Relinquished By: <i>Melissa Gundry</i>	Date: <i>6/1/16</i>	Time: <i>1050</i>	Received By: <i>Melissa Gundry</i>	Date: <i>6/1/16</i>	Time: <i>1050</i>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
TAT: Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>	

REPORT TRANSMITTAL DESIRED:
 HARDCOPY (extra cost) FAX EMAIL ONLINE

FOR LAB USE ONLY
 Temp of samples: *23.3* °C Attempt to Cool?
 Comments: *T-221*



CHAIN OF CUSTODY RECORD

COC ID: 5243

PAGE: 4

OF: 5

ADDRESS
PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040
 FAX: (631) 420-8436
 Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		Pace-Ormond Beach		COMPANY:		Pace-Ormond Beach	
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174		FAX:		(386) 673-4001	
PHONE		(386) 672-5668		EMAIL:			
ACCOUNT #:		70-100281					

SPECIAL INSTRUCTIONS / COMMENTS
 Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!

ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
19	1605098-019A	KITCHEN/ SINK 2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:32:00 AM	1	
200.8_DW_RT (E200.8)							
20	1605098-020A	KITCHEN/ SINK 3/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:33:00 AM	1	
200.8_DW_RT (E200.8)							
21	1605098-021A	KITCHEN/ SINK 4/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:35:00 AM	1	
200.8_DW_RT (E200.8)							
22	1605098-022A	KITCHEN/ SINK 5/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:39:00 AM	1	
200.8_DW_RT (E200.8)							
23	1605098-023A	KITCHEN/ SINK 6/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:40:00 AM	1	
200.8_DW_RT (E200.8)							
24	1605098-024A	KITCHEN/ HAND SINK/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:43:00 AM	1	
200.8_DW_RT (E200.8)							

Relinquished By: <i>Maria Julez</i>	Date: 6/16/16	Time: 10:50	Received By: <i>Mary Prosser</i>	Date: 5/26/16	Time: 10:50
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
TAT: Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>	

REPORT TRANSMITTAL DESIRED:
 HARD COPY (extra cost) FAX EMAIL ONLINE

FOR LAB USE ONLY
 Temp of samples 23.3 °C Attempt to Cool?
 Comments: T-221

Note: RUSH requests will incur surcharges!



CHAIN OF CUSTODY RECORD

COC ID: 5243

PAGE: 5

OF: 5

ADDRESS
PACE ANALYTICAL
 575 Broad Hollow Road
 Melville, NY 11747
 TEL: (631) 694-3040
 FAX: (631) 420-8436
 Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		COMPANY	
Pace-Ormond Beach		Pace-Ormond Beach	
ADDRESS			
8 East Tower Circle			
CITY, STATE, ZIP			
Ormond Beach, FL 32174			
PHONE		FAX	
(386) 672-5668		(386) 673-4001	
ACCOUNT #:			
70-100281			

SPECIAL INSTRUCTIONS / COMMENTS
 Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!

ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation. Additional Sample Description.
25	1605098-025A	AUDITORIUM HALL/ FOUNTAIN 1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:49:00 AM	1	
	200.8_DW_RT (E200.8)						
26	1605098-026A	AUDITORIUM HALL/ FOUNTAIN 2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:51:00 AM	1	
	200.8_DW_RT (E200.8)						
27	1605098-027A	ROOM 136/ SINK 1/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:54:00 AM	1	
	200.8_DW_RT (E200.8)						
28	1605098-028A	ROOM 136/ SINK 2/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:55:00 AM	1	
	200.8_DW_RT (E200.8)						
29	1605098-029A	ROOM 136/ SINK 3/ R	250mlHDPEHN O3	Potable Water	5/20/2016 6:58:00 AM	1	
	200.8_DW_RT (E200.8)						
30	1605098-030A	ROOM 136/ SINK 4/ R	250mlHDPEHN O3	Potable Water	5/20/2016 7:00:00 AM	1	
	200.8_DW_RT (E200.8)						

Relinquished By: <i>[Signature]</i>	Date: 6/17/16	Time: 1050	REPORT TRANSMITTAL DESIRED: <input type="checkbox"/> HARDCOPY (extra cost) <input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ONLINE FOR LAB USE ONLY Temp of samples: 23.3 °C Attempt to Cool? _____ Comments: 4-221
Relinquished By:	Date:	Time:	
Relinquished By:	Date:	Time:	
TAT: Standard <input type="checkbox"/> RUSH <input checked="" type="checkbox"/>	Next BD <input type="checkbox"/> 2nd BD <input type="checkbox"/> 3rd BD <input type="checkbox"/>		

Sample Condition Upon Receipt Form (SCUR)

Project # **WO# : 35247892**
Project Manager: _____
Client: **PM: VEG** **Due Date: 06/09/16**
CLIENT: PACH2M

Date and Initials of person examining contents: MPD 6/7/16 1050
Label: MPD
Deliver: MPD
pH: _____

Courier: Fed Ex UPS USPS Client Commercial Pace Other _____
Shipping Method: First Overnight Priority Overnight Standard Overnight Ground
Billing: Recipient Sender Third Party Unkown **Cooler Size if Applicable:** _____
Tracking # 7764 5522 5467

Custody Seal on Cooler/Box Present: yes no **Seals intact:** yes no
Packing Material: Bubble Wrap Bubble Bags None Other _____ **Biological Tissue is Frozen:** Yes No N/A
Thermometer Used T-22.1 **Type of Ice:** Wet Blue None Samples on ice, cooling process has begun
Cooler #1 Temperature°C 23.3 (Visual) 0 (Correction Factor) 23.3 (Actual)
Cooler #2 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #3 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual) **Temp should be above freezing to 6°C**
Cooler #4 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #5 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #6 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)

Comments:

Chain of Custody Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature & Sampler Name COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	HNO3 pH<2 HCl pH<2 H2SO4 pH<2 NaOH pH>12 NaOH/ZnOAc pH>9
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: VOA, Coliform, TOC, O&G	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
No Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution (use back for additional comments): _____

Project Manager Review: _____ **Date:** _____